



कार्यालय नगर निगम ग्रेटर जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-302015, राजस्थान)

क्रमांक :- एफ.31()मु.स्वा.अधि./ननिज/2023/77




दिनांक :- 5-07-2023

SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by **Dr. Rashmi Kankaria**, **Cheif Health Officer** from **Nagar Nigam Greater, Jaipur** inspected the **KIDS CLUB SCHOOL** and found that **KIDS CLUB SCHOOL, BUILDING NO 01, PLOT NO B-1-B, B-1-D, B-1-D, B-1-D-1 & B-1-F, SUMER NAGAR VISTA, MAJOR I J SINHA MARG, NEW SANGANER ROAD, MANSAROVER, JAIPUR** has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State / U.T.Govt.

The Certificate is valid upto 31 March, 2024.


(**Dr. Rashmi Kankaria**)
Cheif Health Officer
(**डॉ. राशमि कांकरिया**)
Nagar Nigam Greater Jaipur
मुख्य स्वास्थ्य अधिकारी (मुख्यालय)
नगर निगम ग्रेटर, जयपुर

To,

The Principal,
KIDS CLUB SCHOOL,
BUILDING NO 01, PLOT NO B-1-B,
B-1-D, B-1-D, B-1-D-1 & B-1-F, SUMER NAGAR VISTA,
MAJOR I J SINHA MARG, NEW SANGANER ROAD,
MANSAROVER, JAIPUR.



GWMICC (P) Ltd.

GROUND WATER & MINERAL INVESTIGATION CONSULTANCY CENTRE (P) LTD.

(An ISO 9001 : 2008 Company)



JAL NIKETAN, 5-JHA-2, JAWAHAR NAGAR, JAIPUR - 302004 (RAJ.) INDIA
Phone : 91-141-2650724, 2650543 Mobile : 94140-70292, 98200-67474 Fax : 91-141-4110680
E-mails : (i) groundwaterjaipur@gmail.com (ii) water@groundwaterindia.com Website : www.groundwaterindia.com

Specialisation : Hydrogeological Survey, Rainwater Harvesting Studies, Geoelectric Investigation, Water & Mineral Resources Evaluation, River Potentiality, Artificial Recharge Reservoir & Studies for Grant of CGWA Permission for Ground Water Extraction.

REF: GWMICC/WAT.CERT./622/2025-26

Date: 05 April 2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

This is to certify that an inspection team headed by **Mr. S. K. SRIVASTAVA, Sr. Hydrogeologist** from **Ground Water & Mineral Investigation Consultancy Centre PVT. LTD.** Inspected the **KIDS CLUB SCHOOL CAMPUS, SUMER NAGAR VISTAR, OPP. DHANWANTARI hospital, New Sanganer Road, Mansarovar, Jaipur 302020** on **30 March 2026** and found that the **KIDS CLUB SCHOOL** campus has **SAFE DRINKING WATER FACILITIES** for the students and members of staff of the institution and is Maintaining the hygienic Sanitation Condition in the school building & the campus as per the norms prescribed by the Central / State / U. T. Government. The above certificate is valid for a period of 12 Months.

Signature & Seal

Name : **S. K. SRIVASTAVA**

Designation : **Sr. Hydrogeologist**

To,
The Principal
KIDS CLUB SCHOOL Campus,
Sumer Nagar Vistar,
OPP: Dhanwantari Hospital,
New Sanganer Road, Mansarovar, Jaipur 3020





GROUND WATER & MINERAL INVESTIGATION CONSULTANCY CENTRE (P) LTD.

(An ISO 9001 : 2008 Company)

JAL NIKETAN, 5-JHA-2, JAWAHAR NAGAR, JAIPUR - 302004 (RAJ.) INDIA

Phone: 91-141-2650724, 2650548, Mobile: 94140-70292, 98290-67474 Fax: 91-141-4110000

E-mails: (i) groundwater.jaipur@gmail.com (ii) water@groundwaterindia.com Website: www.groundwaterindia.com

GWMICC (P) Ltd.



Specialisation: Hydrogeological Survey, Rainwater Harvesting Studies, Geoelectric Investigation, Water & Mineral Resources Evaluation, River Potentially, Artificial Recharge Reservoir & Studies for Grant of CGWA Permission for Ground Water Extraction.

REPORT ON CHEMICAL AND BACTEROLOGICAL ANALYSIS OF WATER SAMPLE GIVEN BY KIDS CLUB SCHOOL, JAIPUR AS PER IS 10500-2012 NAORMS.

CHEMICAL EXAMINATION

S. NO.	INGREDIENT	VALUE
1.	COLOUR, HAZEN UNITS	NIL
2.	ODOUR	UNOBJECTIONABLE
3.	TASTE	AGREEABLE
4.	TURBIDITY NTU	1 NTU
5.	pH VALUE	7.98
6.	TOTAL HARDNESS (AS $CaCO_3$) MG/L	81.12 MG/LTR.
7.	IRON (AS FE) MG/L	0.0527 MG/LTR.
8.	CHLORIDES (AS CL) MG/L	36.84 MG/LTR.
9.	TOTAL DISSOLVED SOLIDS MG/L	533.43 MG/LTR.
10.	TOTAL SUSPENDED SOLIDS	13.65 MG/LTR.
11.	CALCIUM (AS CA) MG/L	16.24 MG/LTR.
12.	SULPHATE (AS SO_4) MG/L	22.02 MG/LTR.
13.	NITRATE (AS NO_3) MG/L	43.50 MG/LTR.
14.	FLUORIDE (AS F) MG/L	0.691 MG/LTR.
15.	ALKALINITY MG/L	298.08 MG/LTR.
16.	ALUMINUM (AS AL) MG/L	NIL
17.	BORON MG/L	NIL
18.	SODIUM	86.22 MG/LTR.
19.	POTASSIUM	NIL

MICROBIOLOGICAL EXAMINATION

1.	TOTAL COLLIFORM COUNT (CFU ML) (PER 100 ML MPN)	7 COLIFORM
2.	TEST FOR E-COLIFORM COUNTS (PER 100 ML MPN)	ABSENT
3.	FAECAL COLIFORM (PER 100 ML MPN)	0 COLIFORM

ADDITIONAL REQUIREMENT AS PER ENVIRONMENTAL REGULATION ACT

1.	CHEMICAL OXYGEN DEMAND (C.O.D.)	24.61 MG/LTR.
2.	BIO CHEMICAL OXYGEN DEMAND (B.O.D.) 5 DAYS AT 20 C	6.23 MG/LTR.

INFERENCE:-

The water is with permissible limits as per highest limits of is 10500 for drinking water.



(Authorized Signatory)
FOR GWMICC PVT. LTD

[Handwritten Signature]
5.4/2026